SALUS iT500BM Internet Thermostat



23:45

Product compliance & safety information

These instructions are applicable to the SALUS Controls model stated on the front cover of this manual only, and must not be used with any other make or model.

This accessory must be fitted by a competent person, and installation must comply with the guidance provided in the current IEE Wiring Regulations and current Building Regulations. Failure to comply with the requirements of these publications could lead to prosecution.



When fitting batteries, do not mix old and new batteries together. Do not use rechargeable batteries.

Please leave these instructions with the end user where they should be kept in a safe place for future reference.

Contents of the box



iT500TR Thermostat



iTG500 Gateway



Optional Stand



ADSL Cable



iTA500 Power adaptor



Installation

Please refer to the installation guide. The installation guide also shows how to connect your iT500 thermostat to the internet.



Connection & Control



www.salus-controls.com

For details please refer to page 28 in the installation manual.

LCD Overview

LCD ICONS	DESCRIPTION	FUNCTION
1234567	Day of the week	Displays the number of the day of the week. 1 being Monday
88:	Temperature indicator	Displays set or measured temperature
88:88 [.]	Clock display	Displays time
123458	Program number indicator	Displays the number of the active (selected) program
۵ [.]	Heat mode indicator	Indicates heating output is turned on*
	Heat indicator	Indicates heating zone
11	Hot water mode indicator	Indicates hot water output is turned on*
((193)	RF signal indicator	Indicates the unit is transmitting a wireless signal to the iT500RX or is receiving the signal from the iT300*
	Touch lock indicator	Indicates touch lock is activated
	Battery status	Indicates battery is low
IÊI	Holiday indicator	Indicates holiday operation mode is selected
•	Internet indicator	Indicates connection to iTG500 and SALUS server
AUTO	AUTO indicator	Automatic program mode
OFF	OFF indicator	Off mode
0	Setting indicator	Manual override or settings mode

Controls



iT500BM User Manual 05

System PC & Smartphone Control



Energy save will use the lowest set temperature on your daily schedule.



Will be displayed when the current program has been manually overridden.

AUTO *Press AUTO to cancel temporary override of program temperature.

HEATING				
AUTO CAUES OFF	ALL MON-FRI	Thursday 15/08/2	013 11:49 18 am	
	Program 1	7:10 am	21.0 °C	
	2	9:00 am	15.0 °C	
	3	10:40 am	24.0 °C	
	4	12:10 pm	23.0 °C	
	5	2:50 pm	17.5 °C	
HEATING AUTO	6	9:20 pm	15.0 °C	
		Holiday not set	1	
Holday Start: 14-08-2013 1:38 pm				
	Holiday End:	14-08-2013	1:38 pm	

System PC & Smartphone Control



System Local Control

Control available on your Smartphone or PC is also available locally on the iT500.

Temporary override of vour temperature

Press the power button to start and use the huttons indicated to change the SET temperature. Then press the tick to accept.

08



System PC & Smartphone Control

Switching your heating from AUTO to OFF.

Press the power button to start and use the buttons indicated to switch from AUTO to OFF.

home screen.



Default Program Schedules

Central Heating

PROGRAM	WEEKDAY (1 to 5)	WEEKDAY (6 to 7)	
1	Time 6:00am Setpoint Temp 21ºC	Time 6:00am Setpoint Temp 21°C	
2	Time 8:00am Setpoint Temp 14ºC	Time 8:00am Setpoint Temp 14°C	
3	Time 11:00am Setpoint Temp 21ºC	Time 11:00am Setpoint Temp 21°C	
4	Time 1:00pm Setpoint Temp 14°C	Time 1:00pm Setpoint Temp 14°C	
5	Time 4:00pm Setpoint Temp 21°C	Time 4:00pm Setpoint Temp 21°C	
6	Time 9:00pm Setpoint Temp 14°C	Time 9:00pm Setpoint Temp 14°C	



Viewing or changing your program schedule



Default Program Schedules



12 iT500BM User Manual

Viewing or changing your program schedule



13

Program Menu: Setting Time and Date

When connected to the internet, the iT500 will set the time and date automatically, however this can also be set manually.









Useful information

Exiting Holiday Mode

To exit holiday mode, press and hold the button.





Exiting Energy Mode



*See page 6 for description

Useful information

Cancel Temporary Override

To cancel temporary override of set temperature press and hold



Lock Function



Notes



SALUS Controls plc

SALUS House Dodworth Business Park South, Whinby Road, Dodworth, Barnsley S75 3SP UK.

SALES: T: +44 (0) 1226 323961 E: sales@salus-tech.com

TECHNICAL: T: +44 (0) 1226 323961 E: tech@salus-tech.com

www.salus-controls.com





SALUS Controls is a member of the Computime Group

Maintaining a policy of continuous product development SALUS Controls plc reserve the right to change specification, design and materials of products listed in this brochure without prior notice.

Issue Date: Nov 2013

00086/2